

Nebraska Department of Environment and Energy  
Water Quality Division  
Onsite Wastewater Treatment Program  
(402) 471-4285  
<http://dee.ne.gov>

|                     |
|---------------------|
| NDEE FILE<br>398050 |
|---------------------|

Onsite Wastewater Treatment System  
Registration Receipt

Christopher H Williamson  
71499 Road 362  
Trenton NE 69044 1725

Kari Peter  
PO Box 481  
Trenton NE 69044 0481

RE: System Number TS40233  
NDEEID #119851 R Via Retreat LLC

The following Onsite Wastewater Treatment System has been registered with the Nebraska Department of Environment and Energy as required by *Title 124 - Rules and Regulations for the Design, Operation and Maintenance of Onsite Wastewater Treatment Systems*.

Please note that this registration simply acknowledges receipt by the NDEE of a completed registration form and registration fee (and late fee if applicable), and is not an acknowledgement by the Department that the actual installation complies with the design, setback or other requirements prescribed in regulation.

|   |  |
|---|--|
| Kari Peter<br>PO Box 481<br>Trenton NE 69044 0481 | 71420 Ventures Way<br>Trenton                |
| SW SE Sec 32 Twn N 03 Range W 33                  | Latitude : 40.178758 Longitude : -101.068236 |

|                          |                                |            |
|--------------------------|--------------------------------|------------|
| Christopher H Williamson | OWT Systems Professional #1975 |            |
| New Installation         | 10-13-2023                     | 06-26-2023 |

**DETAILS ON FILE WITH NDEE:**

|  |   |
|--|---|
| <b>Treatment Type =</b> Septic System  |   |
| <b>Design Flow =</b> 600 gpd           | <b>Soil Absorption System =</b> Trench    |
| <b>Depth to Groundwater =</b> 150.0 ft | <b>Effective Bottom Area =</b> 1058 sq ft |
| <b>Percolation Rate =</b> 11-20 min/in | <b>Number of Trenches =</b> 4             |
| <b>Liner =</b>                         | <b>Trench Width =</b> 36 in               |
| <b>Septic Tank Capacity =</b> 1500 gal | <b>Total Trench Length =</b> 292 ft       |
| <b>Garbage Grinder =</b>               | <b>Treatment Media =</b>                  |
| <b>Large Capacity Tub =</b>            | <b>Distribution System =</b> Chambers     |

If any of this information is incorrect, please contact the **NDEE Onsite Wastewater Treatment Program** at **402-471-4285** with the correct information.



20230964505

Nebraska Department of Environment and Energy  
Water Quality Division  
Onsite Wastewater Treatment Program  
(402) 471-4285  
<http://dee.ne.gov>

|                     |
|---------------------|
| NDEE FILE<br>119851 |
|---------------------|

Onsite Wastewater Treatment System  
Registration Receipt

Kari Peter  
PO Box 481  
Trenton NE 69044 0481

Christopher H Williamson  
71499 Road 362  
Trenton NE 69044 1725

RE: System Number TS40233  
NDEQID #119851 R Via Retreat LLC

The following Onsite Wastewater Treatment System has been registered with the Nebraska Department of Environment and Energy as required by *Title 124 - Rules and Regulations for the Design, Operation and Maintenance of Onsite Wastewater Treatment Systems*.

Please note that this registration simply acknowledges receipt by the NDEE of a completed registration form and registration fee (and late fee if applicable), and is not an acknowledgement by the Department that the actual installation complies with the design, setback or other requirements prescribed in regulation.

|   |  |
|---|--|
| Kari Peter<br>PO Box 481<br>Trenton NE 69044 0481 | 71420 Ventures Way<br>Trenton                |
| SW SE Sec 32 Twn N 03 Range W 33                  | Latitude : 40.178758 Longitude : -101.068236 |

|                          |                                |            |
|--------------------------|--------------------------------|------------|
| Christopher H Williamson | OWT Systems Professional #1975 |            |
| New Installation         | 10-13-2023                     | 06-26-2023 |

**DETAILS ON FILE WITH NDEE:**

|  |   |
|--|---|
| <b>Treatment Type =</b> Septic System  |   |
| <b>Design Flow =</b> 600 gpd           | <b>Soil Absorption System =</b> Trench    |
| <b>Depth to Groundwater =</b> 150.0 ft | <b>Effective Bottom Area =</b> 1058 sq ft |
| <b>Percolation Rate =</b> 11-20 min/in | <b>Number of Trenches =</b> 4             |
| <b>Liner =</b>                         | <b>Trench Width =</b> 36 in               |
| <b>Septic Tank Capacity =</b> 1500 gal | <b>Total Trench Length =</b> 292 ft       |
| <b>Garbage Grinder =</b>               | <b>Treatment Media =</b>                  |
| <b>Large Capacity Tub =</b>            | <b>Distribution System =</b> Chambers     |

If any of this information is incorrect, please contact the **NDEE Onsite Wastewater Treatment Program** at **402-471-4285** with the correct information.